

**70 CFM/3.5 SONES @ 0.10" WG. -HVI CERTIFIED**  
**120 Volts, 4.6 amps, 60 hz.**

➤ **GRILL**  
 White, polymeric grill (flame retardant ABS UL rated 94-5V) secured in place with torsion springs; easily removed if necessary, dimensions - 16<sup>1/2</sup>"x10".

➤ **BLOWER WHEEL**  
 One piece polymeric wheel, 3<sup>7/8</sup>" diameter, 2<sup>1/2</sup>" wide, with 21 fins.


➤ **MOTOR**  
 Heavy duty, plug-in, 2 pole motor, life time lubrication, thermally protected. Rated 120 volts, 60 hz., 0.90 amps.

➤ **FAN HOUSING**  
 23 gauge galvanized steel housing, dimensions 13<sup>7/8</sup>"x8"x5<sup>7/8</sup>".

➤ **DUCT COLLAR**  
 Plastic collar for 4" duct connection, comes complete with built in non-metallic back draft damper for quiet operation.

➤ **VENTILATED AREA**  
 For bathrooms up to 70 sq. ft.

➤ **LAMPING INFORMATION**  
 2 x 250 watt maximum, type R40 bulb, medium base, 1700 BTU heating.



**TYPE IC RATED**

➤ **UNIT MOUNTING**  
 Rated Type IC for ceilings insulated to R-40. Designed to mount in ceilings with at least 6" of clearance. The unit is centered between joists (with 16" centers) using hanging brackets. The housing will mount through drywall thickness up to 3/4", with a rough-in opening of 13<sup>15/16</sup>"x8<sup>1/16</sup>".

➤ **SINGLE PACK SHIPPING INFO**  
 ➤ Box Dim 18"x11<sup>1/2</sup>"x7<sup>3/4</sup>" ➤ UPC 0-8316227011-5  
 ➤ Shipping Weight - 9 lbs.

HVI PERFORMANCE									
Static pressure (inches of w.g.)	0	0.05	0.1	0.15	0.2	0.25	0.3	0.35	0.4
CFM	77	74	71	68	65	61	57	52	45
RPM	2300	2400	2450	2500	2550	2600	2650	2710	2840
*WATTS	552	553	552	551	551	550	548	547	545

\*wattage readings include 2 heat lamp bulbs, for fan only wattage minus 500 watts

Air-King bathroom fans are tested by the Air Movement and Control Association (AMCA) in accordance with HVI test standard 916, (Air Flow Test Standard) and HVI test standard 915 (Procedure For Loudness Rating Of Residential Fan Products). The Performance results are certified and verified by the Home Ventilating Institute (HVI).

<b>PROJECT</b>							<b>ARCHITECT</b>			
<b>LOCATION</b>							<b>ENGINEER</b>			
<b>CONTRACTOR</b>							<b>SUBMITTED BY</b>			<b>DATE</b>
FAN NUMBER	MODEL NUMBER	CFM	IN W.C.	RPM	WATTS	AMPS	SONES	QTY	OPTIONAL EQUIPMENT & REMARKS	

